

Rheem-Ruud-WeatherKing MH Coil R-22 Ratings Sheet

OUTDOOR UNIT				MANUFACTURED HOUSING INDOOR COIL SELECTION														
A/C	96-8G2T-(*)P			96-8G2T-(*)P			96-8G4X-(*)P			96-8G4X-(*)P			96-8W4X-(*)P			96-8W4X-(*)P		
RHEEM	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR
()AND-018J*Z	13.0	18.1	NO	13.0	18.2	NO												
()AND-024J*Z	13.0	24.0	NO	13.0	24.0	NO												
()AND-030J*Z	13.0	28.8	YES	13.0	29.2	YES	13.0	29.6	YES	13.0	30.0	NO	13.0	30.2	NO			
()AND-036J*Z	13.0	33.4	YES	13.0	33.6	YES	13.0	34.0	YES	13.0	34.6	NO	13.0	34.8	NO			
()AND-042J*Z													13.0	41.0	YES	13.0	42.0	YES
()AND-048J*Z													13.0	46.5	YES	13.0	47.0	YES
()AND-060J*Z																N/A	51.5	YES
()APC-024J*Z				14.4	24.8	YES												
()APC-030J*Z										14.0	29.8	YES						
()APC-036J*Z										14.0	35.4	YES						
()APC-042J*Z																14.0	41.5	YES
()APC-048J*Z																14.0	47.5	YES
()APC-060J*Z																14.0	51.0	YES
13AJA18	13.0	18.3	NO	13.0	18.3	NO												
13AJA24	13.0	23.4	NO	13.0	23.4	NO												
13AJA30	13.0	27.6	YES	13.0	28.2	YES	13.0	28.4	YES	13.0	28.6	NO	13.0	28.6	NO	13.0	28.6	NO
13AJA36	13.0	33.4	YES	13.0	34.0	YES	13.0	34.0	YES	13.0	34.4	NO	13.0	34.4	NO	13.0	34.4	NO
13AJA42													13.0	40.5	YES	13.0	41.5	NO
13AJA48													13.0	46.0	YES	13.0	47.0	YES
13AJA60																N/A	52.0	YES
14AJA18	14.0	18.1	NO	14.0	18.1	NO												
14AJA24	14.0	24.0	NO	14.0	24.0	NO												
14AJA30							14.0	29.6	NO	14.0	29.6	NO						
14AJA36													13.8	35.2	YES	14.0	36.2	NO
14AJA42													13.8	41.0	YES	14.0	42.0	NO
14AJA48													14.0	45.0	YES	14.0	46.0	NO
14AJA60																13.3	50.5	NO
HEAT PUMP																		
RHEEM	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR	SEER	CAP	TDR
()PNE-018J*Z	13.0	18.0	YES	13.0	18.0	YES												
()PNE-024J*Z	13.0	23.6	YES	13.0	24.0	YES												
()PNE-030J*Z							13.0	29.8	YES	13.0	30.0	YES						
()PNE-036J*Z							13.0	35.2	YES	13.0	35.6	YES						
()PNE-042J*Z													13.0	39.5	YES	13.0	41.0	YES
()PNE-048J*Z													13.0	46.0	YES	13.0	46.5	YES
13PJA18	13.0	18.0	YES	13.0	18.0	YES												
13PJA24	13.0	23.8	YES	13.0	24.0	YES												
13PJA30							13.0	29.4	YES	13.0	30.0	YES						
13PJA36							13.0	35.6	YES	13.0	36.0	YES						
13PJA42													13.0	40.0	YES	13.0	41.5	YES
13PJA48													13.0	46.0	YES	13.0	47.0	YES

(*) Designates either -2P for Quick Connect Fittings, -3P Compression Fittings or -0P for Sweat Connect Fittings.

THE ABOVE MANUFACTURED HOUSING INDOOR COILS ARE EQUIPPED WITH A TXV THAT HAS AN INTERNAL CHECK VALVE FOR HEAT PUMP APPLICATIONS WHEN RATED WITH A HEAT PUMP OUTDOOR UNIT. REFER TO ARI OR THE FACTORY FOR PROPERLY MATCHED HEAT PUMP SYSTEMS. A START KIT MAY BE REQUIRED ON TXV COILS IN SHORT CYCLE OR LOW VOLTAGE SITUATIONS.

INDOOR COIL MODEL	INSTALLED R-22 METERING DEVICE SIZES ***	" WIDE	" DEEP	" HIGH	Coil Selection and Downflow Furnace Application
96-862T-(*)P	TXV 1.5-3.0 TON	18	19.6	14	Fits all Gas and Electric Furnace Applications
96-8G2T-(*)P	TXV 1.5-3.0 TON	18	19.6	14	Fits all Gas and Electric Furnace Applications
96-864X-(*)P	TXV 2.5-5.0 TON	18	19.6	18	Fits all Gas and Electric Furnace Applications
96-8G4X-(*)P	TXV 2.5-5.0 TON	18	19.6	18	Fits all Gas and Electric Furnace Applications
96-894X-(*)P	TXV 2.5-5.0 TON	18	19.6	18.5	Fits all Gas and Electric Furnace Applications, slight modification needed Nordyne M3
96-8W4X-(*)P	TXV 2.5-5.0 TON	18	19.6	18.5	Fits all Gas and Electric Furnace Applications, slight modification needed Nordyne M3

*** The size Metering Device is based on a Range of Applications. The Combination Indoor Coil and Metering Device plus the relationship to the Outdoor Unit determines the Specific ARI Ratings. Proper Metering Devices are required in all applications. TXVs enhance the SEER only.